



State of Utah

DEPARTMENT OF NATURAL RESOURCES
DIVISION OF WATER RIGHTS

Norman H. Bangerter
Governor
Dee C. Hansen
Executive Director
Robert L. Morgan
State Engineer

Southern Area
130 North Main Street
P.O. Box 563
Richfield, Utah 84701-0563
801-896-4429

RECEIVED

MAY 08 1992

WATER RIGHTS
SALT LAKE

May 7, 1992

CERTIFIED MAIL - RETURN REQUESTED
NUMBER P 886 805 627

John T. Alexander
P.O. Box 1464
Rancho Santa Fe, California 92067-1464

RE: New Diversion Structures in Torrey Canal

Dear Sir:

At the request of Torrey Canal Company, this office conducted a field survey of the new diversions that you are installing in the Torrey Canal to facilitate the installation of gated pipe. It was evident from this inspection that the design of your system does not include any measurement devices to measure the water diverted.

Section 73-5-4, Utah Code Annotated, 1964, requires "Every person using water in this state shall construct or install and maintain a substantial head gate, cap, valve or other controlling works, weir flume and measuring device at each point where water is diverted or turned out, for the purpose of regulating and measuring the quantity of water that may be used."

The purpose of this letter is to inform you that you are required by law to install adequate measuring devices to measure the quantity of water that is diverted. Please submit to this office your plans on how you intend to measure the water that you divert. We can then instruct the river commissioner on how to deliver your water.

Sincerely,

Kirk Forbush, P.E.
Regional Engineer

KF/TM/cr

cc: Lee Sim, Assistant State Engineer
Bobby Edwards, River Commissioner